

Stricken language would be deleted from and underlined language would be added to present law.

State of Arkansas
91st General Assembly
Regular Session, 2017

A Bill

HOUSE BILL 1635

By: Representative Eaves

For An Act To Be Entitled

AN ACT TO AMEND THE LAW CONCERNING UNDERGROUND STORAGE TANKS AND SECONDARY CONTAINMENT; AND FOR OTHER PURPOSES.

Subtitle

TO AMEND THE LAW CONCERNING UNDERGROUND STORAGE TANKS AND SECONDARY CONTAINMENT.

BE IT ENACTED BY THE GENERAL ASSEMBLY OF THE STATE OF ARKANSAS:

SECTION 1. Arkansas Code § 8-7-816(a)(1), concerning secondary containment for underground storage tanks, is amended to read as follows:

(a)(1) Each new underground storage tank or piping connected to any new underground storage tank ~~installed after July 1, 2007,~~ shall be secondarily contained and monitored for leaks ~~if the new underground storage tank or piping is within one thousand feet (1,000') of any existing community water system or any existing potable drinking water well.~~

SECTION 2. Arkansas Code § 8-7-816(b)(1), concerning secondary containment for underground storage tanks, is amended to read as follows:

(b)(1) Any existing underground storage tank or existing piping connected to ~~such an~~ an existing underground storage tank that is replaced ~~after July 1, 2007,~~ shall be secondarily contained and monitored for leaks ~~if the replaced underground storage tank or piping is within one thousand feet (1,000') of any existing community water system or any existing potable drinking water well.~~



SECTION 3. Arkansas Code § 8-7-816(b)(3), concerning secondary containment for underground storage tanks, is repealed.

~~(3) With respect to piping, "replace" means to remove and put back in more than five feet (5') of piping associated with a single underground storage tank.~~

SECTION 4. Arkansas Code § 8-7-816(c)(1), concerning secondary containment for underground storage tanks, is amended to read as follows:

(c)(1) Each installation of a new motor fuel dispenser system or replacement of an existing motor fuel dispenser system ~~after July 1, 2007,~~ shall include under-dispenser spill containment ~~if the new or replaced dispenser is within one thousand feet (1,000') of any existing community water system or any existing potable drinking water well.~~